City of Carroll

112 E. 5th Street Carroll, Iowa 51401-2799 (712) 792-1000 FAX: (712) 792-0139

MEMO TO: Mike Pogge-Weaver, City Manager MPW

FROM: Jack Wardell, Director of Parks and Recreation JW

DATE: January 3, 2017

SUBJECT: Report of Bid Opening – Recreation Center Fire Alarm Replacement – Carroll Recreation Center

Pre Bid Estimate: F.Y. 2016-17 - Budgeted Item $48,000.00

On January 4, 2017 two bid proposals were received at the time of the bid opening and the result is listed below:

Drees Company – Carroll, Iowa	$13,999.00
Ed M. Feld Equipment Company, Inc – Carroll, Iowa	$15,433.00

This project included replacement of the existing fire alarm system with a Fire Lite 9600 system. The contractor will perform demolition and replacement for every device located in the Carroll Recreation Center facility. The project will also include a fire alarm panel. This is the first step to replace all existing devises, panel, and battery backup. The new panel will be able to handle the current and future building needs. We will plan on bringing the building up to code in phases.

Listed below are the devices being changed out during this phase along with the panel.

Smoke Detector	Classrooms	Main lobby
Smoke Detector	Classrooms	Main lobby
Smoke Detector	Classrooms	North Hall doors
Smoke Detector	Classrooms	North Hall doors
Smoke Detector	Stage	East
Smoke Detector	Stage	West
Smoke Detector	Stage	Upper stage storage
Duct Detector	AHU 6	East Mezzanine
Duct Detector	AHU 6	East Mezzanine
Duct Detector	Rec Area AHU 5	Center Mezzanine
Duct Detector	Rec Area AHU 5	Center Mezzanine
Duct Detector	AHU 1 & 4	

Duct Detector	Stage AHU 3	
Duct Detector	Classrooms	
Duct Detector	Classrooms	
Pull Station	Rec Area	East Entry
Pull Station	Classrooms	South Entry
Pull Station	Classrooms	West Entry
Pull Station	Classrooms	South Entry
Heat Detector	Classrooms	Janitor closet
Heat Detector	Classrooms	Aerobics Room
Heat Detector	Classrooms	Aerobics Storage
Heat Detector	Classrooms	Men's RR
Heat Detector	Classrooms	Women's RR
Heat Detector	Classrooms	Office Storage
Heat Detector	Classrooms	Activity Kitchenette
Heat Detector	Classrooms	Kitchen Pantry
Heat Detector	Classrooms	Activity Storage
Heat Detector	Classrooms	Crafts Room
Heat Detector	Classrooms	Kitchen - Crafts Room
Heat Detector	Classrooms	Crafts Room Storage
Heat Detector	Classrooms	Crafts Room Storage
Heat Detector	Stage	Theatre Room
Heat Detector	Stage	Theatre Room
Heat Detector	Stage	Theatre Room
Heat Detector	Stage	Theatre Room
Heat Detector	Rec Area AHU 5	Women's RR
Heat Detector		Control Desk
Heat Detector		Gym Storage
Heat Detector		Men's RR
Heat Detector		Janitor closet
Heat Detector	Rec Area AHU 5	Fitness Room Closet
Heat Detector	Rec Area AHU 5	Gym Storage
Heat Detector	Rec Area AHU 5	Family Change
Heat Detector	Rec Area AHU 5	Family Change

RECOMMENDATION: For the Mayor and City Council to consider and approval of the responsible bid from Drees Company – Carroll, Iowa for the bid price of $13,999.00

CITY OF CARROLL
Department of Parks & Recreation
112 E. 5th Street
CARROLL, IOWA 51401
(712) 792-1000

For: Recreation Center Fire Alarm Replacement

Bids were opened on: January 4, 2017 @ 11:00 am

Supplier	Total
1. Drees Company - Carroll, Iowa	$13,999.00
2. Ed M. Feld Equipment Company, Inc. - Carroll, Iowa	$15,433.00
3.	
4.	

Signature: Laura A Schaefer, City Clerk

Date: 01/04/2017